

UQGS.S8368 - Heat-automatic Fire Detectors

Heat-automatic Fire Detectors

POTTER ELECTRIC SIGNAL CO L L C

1609 PARK 370 PL

HAZELWOOD, MO 63042-4417 United States

S8368

Model No.		Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft) Smooth Ceiling	to Wall or Partition
PAD300-HD, PAD300-HD-I		FT/ROR	D4	-	135, 185	70	37.5

Base Model	Related Detector	Control Unit Compatibility Restrictions
PAD300-IB, PAD300-RB	PAD300-HD	B3

B3 - For connection to a Listed open area protection smoke or heat detector head with which compatibility was determined by test or a review of circuit parameters. Refer to the manufacturer's installation instructions for a list of compatible models.

D4 - For connection to any manufacturer's Listed compatible control unit.

FT/ROR - Fixed temperature/rate of rise combination

Trademark and/or Tradename: 

Last Updated on 2022-12-08

并不是所有出现在本数据库中的公司名称和产品都满足了UL 跟踪检验服务的要求。只有带有 UL 标志的产品，才应该被视为经过 UL 认证，并满足UL 跟踪检验服务的要求。注意查看产品上的标志。

UL 允许在线认证目录中所含材料的复制遵循以下条件：1.指南信息、装配、构造、设计、系统和/或认证（文件）必须在不篡改任何数据（或图纸）的情况下完整且无误导性地呈现。2.“经 UL 允许从在线认证目录转载”声明必须出现在所摘取材料的邻近位置。此外，转载材料必须包含以下格式的版权声明： "©2023 UL LLC."